
WATER QUALITY DATA July 2019





Note:

Above are the results of Electrical Conductivity of the water supplied by MWSC within Male', Hulhumale' and Villimale' for the month of July 2019.

Total Number of samples: 267


Number of samples that comply to EPA standard: 267

100% of the samples tested were within the recommended range.

Electrical conductivity (EC) is a good indicator of the total salinity The maximum allowable range for Electrical conductivity is < 1000 μ S/cm Water with EC below <700 μ S/cm is considered ideal for drinking Water with EC above >1500 μ S/cm can make the water saltier

WATER QUALITY DATA July 2019





Note:

Above are the results of pH obtained for the water supplied by MWSC within Male', Hulhumale' and Villimale' for the month of July 2019.

Total Number of samples: 268

Number of samples that comply to EPA standard: 268

100% of the samples tested were within the recommended range.


pH value is a good indicator of whether water is hard or soft and the corrosivity of water The maximum allowable range for pH is 6.5 - 8.5

Water quality with pH ranging from 5 - 6 can have little effect on taste does not have any effects on health

Water quality with pH < 4 and pH >10 can have health impacts

WATER QUALITY DATA July 2019





Note:

Above are the results of Fecal Coliform obtained for the water supplied by MWSC within Male', Hulhumale' and Villimale' for the month of July 2019.

Total Number of samples: 279

Number of samples that comply to EPA standard: 279

100% of the samples tested were within the recommended range.

Fecal coliform is a good indicator of the presence of fecal pollution in water
The maximum allowable limit for fecal coliform is 0
Water quality with fecal coliform ranging from 1 - 10 is unlikely to have Clinical Infections
Water quality with fecal coliform ranging from 10 - 100 can have Clinical Infections
Water quality with fecal coliform >100 can have serious health effects